

Water Testing Results - City View Charter

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Lab #	Test Date	Test Result
Building 1 Drinking Fountain	0160010-04	6/10/2020	5 ppb
Building 1 Boys Bathroom Left	0160010-05	6/10/2020	4 ppb
Building 1 Boys Bathroom Right	0160010-06	6/10/2020	2 ppb
Building 1 Girl's Bathroom Left	0160010-07	6/10/2020	ND
Building 1 Girl's Bathroom Right	0160010-08	6/10/2020	ND
Building 1 Kitchen Left	0160010-09	6/10/2020	2 ppb
Building 1 Kitchen Middle	0160010-10	6/10/2020	3 ppb
Building 1 Kitchen Right	0160010-11	6/10/2020	4 ppb
Building 2 Drinking Fountain	0160010-01	6/10/2020	ND
Building 2 Boys Bathroom	0160010-02	6/10/2020	ND
Building 2 Girls Bathroom	0160010-03	6/10/2020	ND
Building 3 Drinking Fountain	0160010-18	6/10/2020	3 ppb
Building 3 Boys Bathroom Left	0160010-12	6/10/2020	ND
Building 3 Boys Bathroom Right	0160010-13	6/10/2020	ND
Building 3 Girls Bathroom Left	0160010-14	6/10/2020	ND
Building 3 Girls Bathroom Right	0160010-15	6/10/2020	ND
Building 3 Staff Bathroom	0160010-16	6/10/2020	ND
Building 3 2nd Grade Sink	0160010-17	6/10/2020	ND

ND = Non Detect - Lead level is below the set detection limits of 1ppb